



PRIMARY HEALTH CENTRE-SEVNI



Nr. Talav Faliyu, Sevani, Ta.Kamrej Dist. Surat – 394320

Mo. 9727709540 E-Mail : mosevani@yahoo.in Ph. 02621 299521

Dt:-15/06/2022



DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is Certified that Inspection team headed by Dr.Jitesh S.Rana (Medical Officer) From Sevni Primary Health Center Inspected the Satdham Vidyamandir, At & Po.Khanpur village, Ta.Kamrej, Dist.Surat On 15-6-2021 found that The Satdham Vidyamandir is maintaining the hygienic sanitation condition in the school building and also have water purifying unit which supplies pure and safe drinking water to the entire School Building & the Campus as per the norms prescribed by The Central/State/U.T Govt.

The above valid upto

14/06/2023

Signature with seal:

Name:

Dr. Jitesh S. Rana
Medical Officer
Primary Health Center
SEVANI, Tal.Kamrej

Designation:

To
Satdham Vidyamandir,
At & Po.Khanpur.
Ta.Kamrej, Di.Surat
Gujarat-394320



Principal,
Sat Dham Vidyamandir,
Khanpur, Surat.



PRIMARY HEALTH CENTRE-SEVNI



બેટી બચાવો બેટી પઢાવો

NR.TALAV FALIYU, SEVANI, TA.KAMREJ DIST. SURAT – 394320

MO. 9727709540

E-MAIL: mosevani@yahoo.in

PH. 02621 299521

Date: 14/06/2023


DRINKING WATER AND SANITARY CONDITION CERTIFICATE



It is Certified that Inspection team headed by Dr.Jitesh S.Rana (Medical Officer) From Sevni Primary Health Center Inspected the Satdham Vidyamandir, At & Po.Khanpur village, Ta.Kamrej, Dist.Surat On 14-6-2023 found that The Satdham Vidyamandir is maintaining the hygienic sanitation condition in the school building and also have water purifying unit which supplies pure and safe drinking water to the entire School Building & the Campus as per the norms prescribed by The Central/State/U.T Govt.

The above valid upto 14/06/2024

Signature with seal:


Medical Officer
Primary Health Centre,
Sevani Ta. Kamrej Dis. Surat

To

Satdham Vidyamandir
At & Po.Khanpur. Ta.Kamrej,
Di.Surat Gujarat-394320



PRIMARY HEALTH CENTRE-SEVNI



બેટી બચાવો બેટી પઢાવો

NR.TALAV FALIYU, SEVANI, TA.KAMREJ DIST. SURAT – 394320

MO. 9727709540

E-MAIL: mosevani@yahoo.in

PH. 02621 299521

Name and Address:- Sat Dham Vidyamandir

Address:- Kamrej- Bardoli road, Ta.Kamrej, Dist.Surat, Khanpur-394320

Type of Sample :- water

Laboratory :- GWSSB DISTRICT LABORATORY, SURAT

Private

Date of Sample:- 15/02/2023

Source of Sample:- Filtered Water

Date of Analysis:- 15/02/2023

Water Sample Test Report

Sr.No.	Quality Characteristic Test	Result	Prescribed Standards a per IS 10500:2012
1.	Turbidity	Clear	Max. 1 NTU.
2.	Taste	Agreeable	Agreeable
3.	Free Residual Chlorine	Absent	Max. 0.2mg/lit.
4.	Odour	Agreeable	Agreeable
5.	PH Value	7.3	6.5 to 8.5
6.	Ammonia (as Total Ammonia-N)	Absent	Max. 0.5mg/lit.
7.	Nitrate (as NO ₃)	Absent	Max. 45mg/lit
8.	Chlorides (as Cl)	07.0	Max. 250mg/lit.
9.	Total Alkalinity (as Calcium Carbonate)	15.0	Max. 200mg/lit.
10.	Total Hardness (as CaCO ₃)	10.0	Max. 200mg/lit.
11.	Total Dissolved Solids	35.0	Max. 500mg/lit.

Opinion:- The Sample is FIT for drinking Purpose, With Respect to the Test Performed above.

J. S. J. J.
MEDICAL OFFICER
Primary Health Center
Sevni, Tal. Kamrej



DISTRICT LABORATORY
Gujarat Water Supply Sewerage Board
SURAT



REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Name & Address

The Principal,
Sat Dham Vidyamandir
Taluka-Kamrej
Surat.

Sender's Ref. No. :

Nil

Ref. Date. :

14/02/2023

Date & Time of Commencing
Examination :

14/02'23

Sample collected by :

Sender

BW No.	SBW-2396
Date of Collection	14/02'23
Date of Arrival at Lab.	14/02'23
Source of Water Sample	of Sat Dham Vidyamandir School
Village	Khanpur
Habitation	Khanpur
Taluka	Kamrej
District	Surat
APHA, AWWA, 9221-D Presence - Absence Coliform Test, @ 37° C
APHA, AWWA, 9221-F Presence - Absence E-Coli Test, @ 37° C
MPN of coliform per 100 ml of sample at 37° C	< 2
MPN of Faecal coliform per 100 ml of sample at 44° C	< 2
Free Chlorine (PPM)	NIL
OPINION FOR POTABILITY :	FIT

Important Note:-

1) '>=' Indicates greater than or equal to, 2) '<' Indicates less than, 3)'P' Indicates Presence, 4)'A' Indicates Absence

NOTE : Table - 6 Bacteriological Quality of Drinking Water (BIS:10500:2012) : Second Rivlison.

- @ All Water Intended for Drinking -
 - (a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.
- @ Treated Water Entering the Distribution system & Treated Water in the Distribution system -
 - (a) E.coli or Thermotolerant coliform bacteria shall not be detectable in any 100ml sample.
 - (b) Total coliform bacteria shall not be detectable in any 100ml sample.
- @ 0.2ppm Free Residual Chlorine at consumer end is recommended.

- 1) Test Report is issued for assessing Bacteriological Fitness as per the BIS 10500:2012 for the given Drinking Water Sample only.
- 2) This Report should not be taken as a basis to getting license from any Government authority.
- 3) After Collection of Bact. Sample, it must be preserved at 4°C and submitted to laboratory within 24hrs.

District Laboratory
Guj. Water Supply & Sew. Board
"JAL BHAVAN" 2nd Floor,
Adajan O/H Water Tank Compound,
Adajan Road, SURAT-395009. Guj.

LABORATORY
INCHARGE

Outward No.: DL SRT / 75 / of 2023, Dt. 15/02/2023

DISTRICT LABORATORY, 2ND FLOOR, JAL BHAVAN, ADAJAN O/H WATER TANK COMPOUND, ADAJAN ROAD, SURAT-395009.